

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. \_\_\_\_\_

Date : 03/01/2025

It is certified that an inspection team headed by Dr. Yogesh  
Sharma, (Medical Superintendent) (Name of Officers  
with designation) from CHC B.B. NAGAR (Name of  
Department/Office) inspected the DELHI CITY SCHOOL,  
B.B. NAGAR, BSR, U.P. (Name & Address of  
the School) on 02/01/2025 and found that the  
DELHI CITY SCHOOL. (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Signature with Seal :

Name

Designation :

Yogesh  
प्रतिष्ठा अधीक्षक  
: सी० एम० सी० बी०बी०नगर  
जुगैपद Yogesh Sharma

To

THE MANAGER  
DELHI CITY SCHOOL  
B.B. NAGAR, BSR, U.P

(Name &amp; Address of the Institution)

Principal  
DELHI CITY SCHOOL  
B.B. Nagar, Bulandshahr, (U.P.)



# District Level Water Analysis Laboratory

## UP Jal Nigam (Rural), Bulandshahr

### TEST REPORT

UTR NO:	:	Lab T-9249	
Sample receipt Date:	:	25-02-2025	
Customer/Party Name	:	DELHI CITY SCHOOL	
Address	:	BLOCK – B.B NAGAR	
Contact No.	:	9050373400	
Date of Sampling	:	27-2-2025	Sample Code: 12
Sample Description	:	27-2-2025	
Quantity	:	1	
Packing details	:		
Analysis Start	:	27-2-2025	
Analysis End	:	27-2-2025	

Water Sample Provided By ..... YOGESH KUMAR

Availability of Equipments:		Availability of reference standards:		Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:		Duration of testing/Time of Report release	02:35p m

### TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.020	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	0.150	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	255	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	210	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	310	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	240	(Mg/L)*
7	Colour	APHA 23 <sup>rd</sup> Edistion	5	15	10	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part ): 2018	Agreeable	Agreeable	Agreeable	Agreeable

Reviewed By

Principal  
DELHI CITY SCHOOL  
B.B. Nagar, Bulandshahr, (U.P.)

Approved By  
Quality Manager

End of Report

